

[13] Schedule**[14] EC-TYPE EXAMINATION CERTIFICATE No Nemko 00ATEX305****[15] Description of Equipment or protective system**

The FY's are valve positioners for single (spring return) or double acting linear motion type control valves and rotary motion control valves.

Type Designation

FY 290
FY 301
FY 302
FY 303

It's minor differences between the positioners. The electronic board's and the software in the Eprom memory are the only things that differ. The electronic boards are shown in the descriptive documents.

Data

FY 290 and FY 301: 45VDC, 25mA, Pressure: 20-100 psi
FY 302/303 : 32VDC, 12mA, Pressure: 20-100 psi

[16] Report No 200005319 composed in total of 26 pages.**Descriptive Documents**

101E008205	Rev.:5	02.07.2000	
101A453500		12/09/2000	
101A453600		12/09/2000	
101A453700		12/09/2000	
101A453800		12/09/2000	
102B004305	Rev.:5	21/01/00	2 sheets
102A022702	Rev.:2	17/02/00	4 sheets
102B028308	Rev.:8	22/12/99	2 sheets
102A031603	Rev.:3	21/11/98	4 sheets
102B042804	Rev.:04	27/01/00	2 sheets
102A032602	Rev.:2	21/01/00	4 sheets
102B028406	Rev.:6	17/03/00	
102A031704	Rev.:4	21/10/99	4 sheets
102B010103	Rev.:03	06/10/98	
102A026701	Rev.:01	17/05/00	2 sheets
102B013801	Rev.:01	29/05/97	2 sheets
102A026801	Rev.:1	31/05/00	3 sheets
102B050701	Rev.:01	21/12/98	2 sheets
102B050601	Rev.:01	21/12/00	2 sheets

[18] Essential Health and Safety Requirements

See item 9

This certificate may only be reproduced in its entirety and without any change, schedule included.

Postal address:
P.O.Box 73 Blindern
N-0314 OSLO, NORWAY

Office address:
Gaustadalléen 30
0373 OSLO

Telephone:
+47 22 96 03 30
Fax:
+47 22 96 05 50

Enterprise number:
NO 974404532

